

## RESULTS REPORT

**REFERENCE:** V136\_240215\_1AGM

### CUSTOMER DATA:

**NAME:** SMART ECO WATER GROUP, S.L  
**Tax ID:** B-56837909  
**ADDRESS:** Avda. Zaragoza, 6

**CLIENT CODE:** C-V136

**CP/TOWN:** 03130 Santa Pola (Alicante)

### SAMPLE DATA:

**DESCRIPTION OF THE SAMPLE:** AFCH (Cold Water for Human)

**SAMPLE MANAGER:** Andrea Montoya

**SAMPLE DATE:** 15-02-24 **TIME:** 08:45 h

**RECEPTION DATE:** 15-02-24

**ANALYSIS START DATE:** 19-02-24

**ANALYSIS END DATE:** 22-02-24

### 1 MICROBIOLOGICAL ANALYSIS

PARAMETERS	RESULT	LEGAL LIMIT	TEST METHOD
Mesophilic aerobes at 22°C	1 x 103 cfu/ml	< 1 x 103 cfu/ml	ITM1-01-5L
Total coliforms	Not Detected/100ml	0 cfu/100 ml	ITM1-04-5L
<i>Escherichia coli</i>	Not Detected/100ml	0 cfu/100 ml	ITM1-03-5L
<i>Clostridium perfringens</i>	Not Detected/100ml	0 cfu/100 ml	ITM1-07-5L
Fecal Enterococcus	Not Detected/100ml	0 cfu/100 ml	ITM1-09-5L

According to RD 3/2023

1: Use of sterile container with crystallized sodium thiosulfate (S2O3Na2.5H2O) to neutralize the bactericidal effect of chlorine. The sample is kept refrigerated from its reception in the laboratory until the day of its processing

Document made, reviewed and electronically signed by: CENTRO  
TECNOLÓGICO DE SEGURIDAD ALIMENTARIA, S.L CIF: B-  
54676580  
Araceli Sánchez-G Valencia Laboratory  
Manager

END OF REPORT Nº V136\_240215\_1AGM  
Issue date: 08/03/2024 Total  
number of pages - 1